

Southwest and Southeast Water Storage Location Study

Matthew Kennedy, PE June 11, 2019



Why is this project necessary?



REGULATORY REQUIREMENT

Ground or elevated storage systems are required for water systems serving more than 150 living units.

- Southwest Water System: appx. 2,200 units
- Southeast Water system: appx. 750 units





KEY FACTS



GLWA Connection Not Economically Feasible




 A 2012 Study investigated various options for connecting some or all of Oakland Township water systems to GLWA water. None of the options were economically feasible.



Iron Removal Not Desired

2017 Survey Results:


Users do not want to invest in centralized iron removal





Chlorine and Phosphate

- Once the new tank is in service, all areas in the SE water system will use chlorine and polyphosphate.
- Change affects the north pressure district only.





PROCESS



Project Objectives

Evaluate Technical Requirements

Perform Cost-Benefit Analysis



Compile Site List

2017 Oakland Township Residents Survey

Board Members Recommendations

Previous Lists from Studies in 2014 and 2015

Database and Geographical Searches - Public & Private

Vacant Land Searches Using Realcomp MLS and CoStar



Site List Refinement

1st
Pass
Criteria

-Within 1,200
feet of existing
water mains
-At least 2 acres
in size

2nd
Pass
Criteria
-Weighted
scoring for each
site

2nd Pass Criteria

Ownership Type: Public/ Private

Parcel Size

Compatibility with Future Treatment

Visibility

Proximity to Homes

Environmental Factors

Wetland / Hydric soils

Constructability

Location Consistent with Resident Survey Results

Adverse Community Impact

2nd Pass Criteria

ID #	Ownership Type	Ownership	Parcel Size	Compatible with future treatment	Visibility	Proximity to Homes	Environmental / Natural Features	Wetland / Hydric soils	Constructability	Resident Survey	Community Impact	TOTAL WEIGHTED SCORE
4	Private	1	2	4	2	2	2	4	2	4	4	27
1	Private	1	2	0	2	2	2	4	2	4	4	23
2	Private	1	2	4	0	0	2	4	2	4	4	23
_11	Private	1	2	0	2	2	2	4	2	4	4	23
_ 3	Private	1	1	4	0	2	2	4	2	2	4	22
_ 7	Private	1	2	4	2	0	0	4	0	4	4	21
31	Private	1	1	4	1	2	2	4	2	2	2	21
_6	Private	1	2	4	2	0	0	4	1	2	4	20
9	Private	1	2	4	1	0	0	4	2	2	2	18
_ 5	Public	2	2	4	1	2	2	0	2	2	0	17
12	Public	0	2	0	2	2	2	4	2	2	0	16
8	Private	1	1	0	1	0	2	4	0	2	4	15
10	Private	1	0	0	0	0	2	4	2	2	2	13
29	Public	2	0	0	0	0	2	4	0	2	2	12



Owner Interactions

16 potential property sellers were approached starting with the highest ranking.

Conceptual site layouts were created for owners that expressed interest in selling or donating property.

County Assessor researched comparable properties to verify fair sale prices.



Technical Analysis

Hydraulic Modeling

System-Wide Infrastructure Improvements

- Ground storage only
- Potential future water treatment to function with a remote or adjacent storage site

Provided Conceptual Pricing for each Option at each Site





CONCEPTUAL PRICING



SE System Pricing*

750 Users

	Oakland Farms	Bear Creek	Property C	Property D
Ground Storage	\$3.93 M	\$4.30 M	\$4.23 M	\$5.28 M
Property	n/a	n/a	\$0.70 M	\$0.20 M
Total	\$3.93 M	\$4.30 M	\$4.93 M	\$5.48 M



^{*}Based on 2017-2018 construction prices

SW System Pricing*

2,200 Users

	The Crossings	Property F	Property G
Ground Storage	\$4.46 M	\$4.52 M	\$5.02 M
Property	0	Unknown	\$0.58 M
Total	\$4.46 M	\$4.52 M +Property Cost	\$5.60 M



^{*}Based on 2017-2018 construction prices



SUMMARY



SE System Pros & Cons

	Pros	Cons	Cost per household over low option
Oakland Farms Pump House*	• Most economical	Costly future treatment,Social Impact	low option
Bear Creek*	System reliability	Removes parkland,Social impact	+\$450
Private C*	System reliability	• High capital cost	+\$1,217
Private D*	System reliability	High capital cost,High operating cost	+\$1,886

^{*}Assumes Potential Future Treatment Plant at Oakland Farms



SW System Pros & Cons

The Crossings Pump House*	Pros • Most economical (for storage)	Cons • Costly future treatment, • Social impact	Cost per household over low option low option
Private F*	Minimal social impact,System reliability,Low cost	Timeline,Conditions of the sale of property,Availability of Property	+28
Private G*	• System reliability	Higher capital cost,High operating cost	+\$518

^{*}Assumes Potential Future Treatment Plant at The Crossings Pump House



Expected Rate Changes

SE System - Most Economical Location \$38.06/MEU/quarter or

\$9/Mcf \$16/Mcf

SW System - Most Economical Location \$39.43/MEU/quarter or

\$9/Mcf \$9/Mcf



Schedule

Siting Study

• Jan 2018 - Jan 2019

Property Investigations

• Jun 2018 - Dec 2018

Township Board Site Consideration

• Jan 2019 - June 2019

Preliminary Engineering

• Aug 2019 - Nov 2019

Design Phase Engineering

• Oct 2019 - Aug 2020

Construction Phase

• Nov 2020 - Sep 2021

